



CE/EMC TEST REPORT

For

Shenzhen Honestar Electronic tech co.,Ltd

Product Name:	USB Wall Charger
Trademark:	N/A
Model Number:	HS-H43E3U4A8
Prepared For:	Shenzhen Honestar Electronic tech co.,Ltd
Address:	4F, Block B, Yuxing tech & Industry Park, Nanchang, Gushu, Xixiang Street, Bao'an District, Shenzhen, China
Prepared By:	Shenzhen BCTC Testing Co., Ltd.
Address:	BCTC Building & 1-2F, East of B Building, Pengzhou Industrial, Fuyuan 1st Road, Qiaotou Community, Fuyong Street, Bao'an District, Shenzhen, China
Report No.:	BCTC-FY180804578E



TABLE OF CONTENT

Test Report Declaration	Page
1. GENERAL INFORMATION.....	5
1.1. Description of Device (EUT).....	5
1.2. Tested System Details.....	6
1.3. Test Uncertainty.....	6
1.4. Test Facility.....	6
2. TEST INSTRUMENT USED.....	7
3. CONDUCTED EMISSION AT THE MAINS TERMINALS TEST.....	10
3.1. Block Diagram Of Test Setup.....	10
3.2. Test Standard.....	10
3.3. Power Line Conducted Emission Limit.....	10
3.4. EUT Configuration on Test.....	10
3.5. Operating Condition of EUT.....	10
3.6. Test Procedure.....	11
3.7. Test Result.....	11
4. RADIATION EMISSION TEST.....	14
4.1. Block Diagram of Test Setup.....	14
4.2. Test Standard.....	14
4.3. Radiation Limit.....	14
4.4. EUT Configuration on Test.....	15
4.5. Operating Condition of EUT.....	15
4.6. Test Procedure.....	15
4.7. Test Result.....	15
5. HARMONIC CURRENT EMISSION TEST.....	18
5.1. Block Diagram of Test Setup.....	18
5.2. Test Standard.....	18
5.3. Operating Condition of EUT.....	18
5.4. Test Procedure.....	18
5.5. Test Results.....	18
6. VOLTAGE FLUCTUATIONS & FLICKER TEST.....	19
6.1. Block Diagram of Test Setup.....	19
6.2. Test Standard.....	19
6.3. Operating Condition of EUT.....	19
6.4. Test Procedure.....	19
6.5. Test Results.....	19
7. ELECTROSTATIC DISCHARGE IMMUNITY TEST.....	21
7.1. Block Diagram of Test Setup.....	21
7.2. Test Standard.....	21
7.3. Severity Levels and Performance Criterion.....	21
7.4. EUT Configuration.....	22
7.5. Operating Condition of EUT.....	22
7.6. Test Procedure.....	22
7.7. Test Results.....	23
8. RF FIELD STRENGTH SUSCEPTIBILITY TEST.....	24
8.1. Block Diagram of Test Setup.....	24
8.2. Test Standard.....	24
8.3. Severity Levels and Performance Criterion.....	25
8.4. EUT Configuration on Test.....	25
8.5. Operating Condition of EUT.....	25
8.6. Test Procedure.....	26



8.7.	Test Results.....	26
9.	ELECTRICAL FAST TRANSIENT/BURST IMMUNITY TEST.....	27
9.1.	Block Diagram of EUT Test Setup	27
9.2.	Test Standard.....	27
9.3.	Severity Levels and Performance Criterion.....	27
9.4.	EUT Configuration on Test.....	28
9.5.	Operating Condition of EUT	28
9.6.	Test Procedure	28
9.7.	Test Results.....	29
10.	SURGE TEST	30
10.1.	Block Diagram of EUT Test Setup	30
10.2.	Test Standard.....	30
10.3.	Severity Levels and Performance Criterion.....	30
10.4.	EUT Configuration on Test.....	31
10.5.	Operating Condition of EUT	31
10.6.	Test Procedure	31
10.7.	Test Result.....	32
11.	INJECTED CURRENTS SUSCEPTIBILITY TEST	33
11.1.	Block Diagram of EUT Test Setup	33
11.2.	Test Standard.....	33
11.3.	Severity Levels and Performance Criterion.....	33
11.4.	EUT Configuration on Test.....	34
11.5.	Operating Condition of EUT	34
11.6.	Test Procedure	34
11.7.	Test Result.....	35
12.	MAGNETIC FIELD IMMUNITY TEST	36
12.1.	Block Diagram of Test Setup	36
12.2.	Test Standard.....	36
12.3.	Severity Levels and Performance Criterion.....	36
12.4.	EUT Configuration on Test.....	37
12.5.	Operating Condition of EUT	37
12.6.	Test Procedure	37
12.7.	Test Results.....	37
13.	VOLTAGE DIPS AND INTERRUPTIONS TEST	38
13.1.	Block Diagram of EUT Test Setup	38
13.2.	Test Standard.....	38
13.3.	Severity Levels and Performance Criterion.....	38
13.4.	EUT Configuration on Test.....	39
13.5.	Operating Condition of EUT	39
13.6.	Test Procedure	39
13.7.	Test Result.....	39
14.	EUT PHOTOGRAPHS	40
15.	EUT TEST PHOTOGRAPHS.....	43



Shenzhen BCTC Testing Co., Ltd.

Applicant : Shenzhen Honestar Electronic tech co.,Ltd

Address : 4F, Block B, Yuxing tech & Industry Park, Nanchang, Gushu, Xixiang Street, Bao'an District, Shenzhen, China

Manufacturer : Shenzhen Honestar Electronic tech co.,Ltd

Address : 4F, Block B, Yuxing tech & Industry Park, Nanchang, Gushu, Xixiang Street, Bao'an District, Shenzhen, China

EUT : USB Wall Charger

Model Number : HS-H43E3U4A8

Trademark: : N/A

Test Date : Aug. 14 – Aug. 16, 2018*

Date of Report : Aug. 16, 2018

Test Result: : The equipment under test was found to be compliance with the requirements of the standards applied.

*:retest RS CS

Test Procedure Used:

EMI : EN 55032:2015

EN 61000-3-2:2014, EN 61000-3-3:2013

EMS : EN 55035:2017

EN 61000-4-2:2009, EN 61000-4-3:2006+A1:2008+A2:2010,

EN 61000-4-4:2012, EN 61000-4-5:2014,

EN 61000-4-6:2014, EN 61000-4-8:2010, EN 61000-4-11:2004

Prepared by(Engineer): Icey Chen

Icey Chen

Reviewer(Supervisor): Rita Xiao

Rita Xiao

Approved(Manager): Carson Zhang

Carson Zhang



This test report is based on a single evaluation of one sample of above mentioned products. It is not permitted to be duplicated in extracts without written approval of Shenzhen BCTC Testing Co., Ltd.



1. GENERAL INFORMATION

1.1. Description of Device (EUT)

EUT : USB Wall Charger

Trademark : N/A

Model Number : HS-H43E3U4A8
See the following table model differences

Model Difference : The product is different for model number and outlook color.

Power Supply : AC110V-240V 50/60Hz
DC 5V 4.8A 24W

Note: HS-H43E3U4A8 was selected as the test model and the datas have been recorded in this report.

Model Number	
HS-H43ETC4A8	HS-H43A3U3A4
HS-H43BTC4A8	HS-H43U3U3A4
HS-H43ATC4A8	HS-H43E2U3A4
HS-H43UTC4A8	HS-H43B2U3A4
HS-H43E3U4A8	HS-H43A2U3A4
HS-H43B3U4A8	HS-H43U2U3A4
HS-H43A3U4A8	HS-H43E3U3A1
HS-H43U3U4A8	HS-H43B3U3A1
HS-H43E2U4A8	HS-H43A3U3A1
HS-H43B2U4A8	HS-H43U3U3A1
HS-H43A2U4A8	HS-H43E2U3A1
HS-H43U2U4A8	HS-H43B2U3A1
HS-H43E3U4A2	HS-H43A2U3A1
HS-H43B3U4A2	HS-H43U2U3A1
HS-H43A3U4A2	HS-H43E2U2A4
HS-H43U3U4A2	HS-H43B2U2A4
HS-H43E2U4A2	HS-H43A2U2A4
HS-H43B2U4A2	HS-H43U2U2A4
HS-H43A2U4A2	HS-H43E1U2A4
HS-H43U2U4A2	HS-H43B1U2A4
HS-H43E3U3A4	HS-H43A1U2A4
HS-H43B3U3A4	HS-H43U1U2A4



1.2. Tested System Details

Personal Computer	: ASUS	Monitor	: SONY
M/N	: A1580TW	M/N	: MNT1
Printer	: EPSON STYLUS	Keyboard (USB)	: Genuine
M/N	: P320A	M/N	: N/A
Modem	: ACEEX	Mouse	: DETROIS
M/N	: DM-1414	M/N	: CM309

1.3. Test Uncertainty

Conducted Emission : ± 1.82 dB
Uncertainty

Radiated Emission Uncertainty : ± 2.51 dB

1.4. Test Facility

Site Description

Name of Firm	: Shenzhen BCTC Testing Co., Ltd.
Site Location	: BCTC Building & 1-2F, East of B Building, Pengzhou Industrial, Fuyuan 1st Road, Qiaotou Community, Fuyong Street, Bao'an District, Shenzhen, China
Lab Qualifications	: Certificated by Industry Canada Registration No.: 12655A Date of registration: January 19, 2015 Certificated by FCC, USA Registration No.: 187086 Date of registration: November 28, 2014 Certificated by CNAS China Registration No.: CNAS L6046 Date of registration: February 3, 2013



2. TEST INSTRUMENT USED

For Conducted Emission at the mains terminals Test

Conducted Emission Test (A --- site)					
Equipment	Manufacturer	Model#	Serial#	Last Cal.	Next Cal.
843 Shielded Room	ChengYu	843 Room	843	Aug. 25, 2017	Aug. 24, 2018
EMI Receiver	R&S	ESCI	101421	Aug. 27, 2017	Aug. 26, 2018
LISN	Schwarzbeck	NSLK8127	8127739	Sep. 07, 2017	Sep. 06, 2018
Attenuator	R&S	ESH3-Z2	BCTC021E	Aug. 25, 2017	Aug. 24, 2018
843 Cable 1#	FUJIKURA	843C1#	001	Aug. 25, 2017	Aug. 24, 2018

For Conducted Emission at the telecom port Test

Conducted Emission Test (A --- site)					
Equipment	Manufacturer	Model#	Serial#	Last Cal.	Next Cal.
843 Shielded Room	ChengYu	843 Room	843	Aug. 25, 2017	Aug. 24, 2018
EMI Receiver	R&S	ESCI	101421	Aug. 27, 2017	Aug. 26, 2018
Coupling/ Decoupling Network	PH	ISN T800	S1509001	Aug. 25, 2017	Aug. 24, 2018
Attenuator	R&S	ESH3-Z2	BCTC021E	Aug. 25, 2017	Aug. 24, 2018
843 Cable 1#	FUJIKURA	843C1#	001	Aug. 25, 2017	Aug. 24, 2018

For Radiated Emission Test

Radiation Emission Test (966 chamber)					
Equipment	Manufacturer	Model#	Serial#	Last Cal.	Next Cal.
966 chamber	ChengYu	966 Room	966	Aug. 25, 2017	Aug. 24, 2018
Spectrum Analyzer	Agilent	E4407B	MY45109572	Aug. 27, 2017	Aug. 26, 2018
Amplifier	Schwarzbeck	BBV9743	9743-119	Aug. 25, 2017	Aug. 24, 2018
Amplifier	Schwarzbeck	BBV9718	9718-270	Aug. 25, 2017	Aug. 24, 2018
Log-periodic Antenna	Schwarzbeck	VULB9160	VULB9160-3369	Sep. 07, 2017	Sep. 06, 2018
EMI Receiver	R&S	ESCI	101421	Aug. 27, 2017	Aug. 26, 2018
Horn Antenna	Schwarzbeck	BBHA9120D	9120D-1275	Aug. 25, 2017	Aug. 24, 2018
966 Cable 1#	CHENGYU	966	004	Aug. 25, 2017	Aug. 24, 2018
966 Cable 2#	CHENGYU	966	003	Aug. 25, 2017	Aug. 24, 2018



For Harmonic & Flicker Test

For Harmonic / Flicker Test (A --- site)					
Equipment	Manufacturer	Model#	Serial#	Last Cal.	Next Cal.
Harmonic / Flicker Analyzer	KIKUSUI	KHA1000	VA002445	Sep. 06 2017	Sep. 06, 2018
AC Power Supply	KIKUSUI	PCR4000M	UK001879	Sep. 06 2017	Sep. 06, 2018
Line Impedance network	KIKUSUI	LIN1020JF	UL001611	Sep. 06 2017	Sep. 06, 2018

For Electrostatic Discharge Immunity Test

For Electrostatic Discharge Immunity Test (A --- site)					
Equipment	Manufacturer	Model#	Serial#	Last Cal.	Next Cal.
ESD Tester	KIKUSUI	KES4201A	UH002321	Aug. 28, 2017	Aug. 27, 2018

For RF Field Strength Susceptibility Test(SMQ)

For RF Field Strength Susceptibility Test (SMQ --- site)					
Equipment	Manufacturer	Model#	Serial#	Last Cal.	Next Cal.
Signal Generator	HP	8648A	3625U00573	Sep. 26, 2017	Sep. 26, 2018
Amplifier	A&R	500A100	17034	Sep. 26, 2017	Sep. 26, 2018
Amplifier	A&R	100W/1000M1	17028	Sep. 26, 2017	Sep. 26, 2018
Audio Analyzer (20Hz~1GHz)	Panasonic	2023B	202301/428	Sep. 26, 2017	Sep. 26, 2018
Isotropic Field Probe	A&R	FP2000	16755	Sep. 26, 2017	Sep. 26, 2018
Antenna	EMCO	3108	9507-2534	Sep. 26, 2017	Sep. 26, 2018
Log-periodic Antenna	A&R	AT1080	16812	Sep. 26, 2017	Sep. 26, 2018



For Electrical Fast Transient /Burst Immunity Test

For Electrical Fast Transient/Burst Immunity Test (A --- site)					
Equipment	Manufacturer	Model#	Serial#	Last Cal.	Next Cal.
Burst Tester	Prima	EFT61004AG	PR14054467	Aug. 25, 2017	Aug. 24, 2018
Coupling Clamp	Prima	EFT61004AG	BCTC009E	Aug. 25, 2017	Aug. 24, 2018

For Surge Test

For Surge Test (A --- site)					
Equipment	Manufacturer	Model#	Serial#	Last Cal.	Next Cal.
Surge Tester	Prima	SUG61005BX	PR12045446	Aug. 27, 2017	Aug. 26, 2018

For Injected Currents Susceptibility Test

For Injected Currents Susceptibility Test (A --- site)					
Equipment	Manufacturer	Model#	Serial#	Last Cal.	Next Cal.
C/S Test System	SCHLODER	CDG600	126B1281	Aug. 27, 2017	Aug. 26, 2018
CDN	SCHLODER	CDN-M2+3	A2210320/2015	Aug. 27, 2017	Aug. 26, 2018
Injection Clamp	SCHLOBER	EMCL-20	132A1214/2015	Aug. 27, 2017	Aug. 26, 2018

For Magnetic Field Immunity Test


For Magnetic Field Immunity Test (A --- site)					
Equipment	Manufacturer	Model#	Serial#	Last Cal.	Next Cal.
Magnetic field generator	HTEC	HPFMF	15701	Aug. 27, 2017	Aug. 26, 2018

For Voltage Dips Interruptions Test

For Voltage Dips Interruptions Test (A --- site)					
Equipment	Manufacturer	Model#	Serial#	Last Cal.	Next Cal.
Dips Tester	Prima	DRP61011AG	PR14086284	Aug. 27, 2017	Aug. 26, 2018

3. CONDUCTED EMISSION AT THE MAINS TERMINALS TEST

3.1. Block Diagram Of Test Setup



3.2. Test Standard

EN 55032:2015

3.3. Power Line Conducted Emission Limit

Frequency MHz	Limits dB(μ V)	
	Quasi-peak Level	Average Level
0.15 ~ 0.50	66 ~ 56*	56 ~ 46*
0.50 ~ 5.00	56	46
5.00 ~ 30.00	60	50

Notes: 1. *Decreasing linearly with logarithm of frequency.
2. The lower limit shall apply at the transition frequencies.

3.4. EUT Configuration on Test

The following equipments are installed on conducted emission test to meet EN 55032 requirement and operating in a manner which tends to maximize its emission characteristics in a normal application.

3.5. Operating Condition of EUT

3.5.1 Setup the EUT and simulators as shown in Section 3.1.

3.5.2 Turn on the power of all equipments.

3.5.3 Let the EUT work in test modes and test it.



3.6. Test Procedure

The EUT is put on the ground and connected to the AC mains through a Artificial Mains Network (AMN). This provided a 50ohm coupling impedance for the tested equipments. Both sides of AC line are checked to find out the maximum conducted emission levels according to the **EN 55032** regulations during conducted emission test.

The bandwidth of the test receiver (R&S Test Receiver ESCI) is set at 10KHz.

The frequency range from 150 KHz to 30 MHz is investigated.

3.7. Test Result


PASS

Please refer to the following page.



Conducted Emission At The Mains Terminals Test Data

Temperature:	24.5 °C	Relative Humidity:	54%
Pressure:	1009hPa	Phase :	Line
Test Voltage :	AC 230V/50Hz	Test Mode:	On mode




No.	Mk.	Freq.	Reading Level	Correct Factor	Measure-ment	Limit	Over		
		MHz	dBuV	dB	dBuV	dBuV	dB	Detector	Comment
1		0.4785	38.59	9.68	48.27	56.37	-8.10	QP	
2		0.4785	29.38	9.68	39.06	46.37	-7.31	AVG	
3		0.6449	38.11	9.67	47.78	56.00	-8.22	QP	
4		0.6449	22.77	9.67	32.44	46.00	-13.56	AVG	
5		1.0274	37.58	9.71	47.29	56.00	-8.71	QP	
6		1.0274	21.77	9.71	31.48	46.00	-14.52	AVG	
7	*	2.2019	39.18	9.72	48.90	56.00	-7.10	QP	
8		2.2019	22.65	9.72	32.37	46.00	-13.63	AVG	
9		2.6070	38.31	9.72	48.03	56.00	-7.97	QP	
10		2.6070	21.30	9.72	31.02	46.00	-14.98	AVG	
11		5.1045	35.96	9.74	45.70	60.00	-14.30	QP	
12		5.1045	19.88	9.74	29.62	50.00	-20.38	AVG	



Conducted Emission At The Mains Terminals Test Data


Temperature:	24.5 °C	Relative Humidity:	54%
Pressure:	1009hPa	Phase :	Neutral
Test Voltage :	AC 230V/50Hz	Test Mode:	On mode



No.	Mk.	Freq. MHz	Reading Level dBuV	Correct Factor dB	Measure- ment dBuV	Limit dBuV	Over dB	Detector	Comment
1		0.4785	44.14	9.68	53.82	56.37	-2.55	QP	
2	*	0.4785	36.18	9.68	45.86	46.37	-0.51	AVG	
3		0.5369	41.39	9.68	51.07	56.00	-4.93	QP	
4		0.5369	32.31	9.68	41.99	46.00	-4.01	AVG	
5		1.2254	39.20	9.71	48.91	56.00	-7.09	QP	
6		1.2254	31.13	9.71	40.84	46.00	-5.16	AVG	
7		2.2244	38.86	9.72	48.58	56.00	-7.42	QP	
8		2.2244	28.17	9.72	37.89	46.00	-8.11	AVG	
9		2.6565	37.90	9.72	47.62	56.00	-8.38	QP	
10		2.6565	27.19	9.72	36.91	46.00	-9.09	AVG	
11		4.1100	36.67	9.73	46.40	56.00	-9.60	QP	
12		4.1100	25.18	9.73	34.91	46.00	-11.09	AVG	

4. RADIATION EMISSION TEST

4.1. Block Diagram of Test Setup



4.2. Test Standard

EN 55032:2015

4.3. Radiation Limit

Frequency MHz	Distance (Meters)	Field Strengths Limits dB(μ V)/m	Detector
30 ~ 230	3	40.0	QP
230 ~ 1000	3	47.0	QP
1000 ~ 3000	3	76.0	PEAK
1000 ~ 3000	3	56.0	AVERAGE
3000 ~ 6000	3	80.0	PEAK
3000 ~ 6000	3	60.0	AVERAGE

Remark:

- (1) Emission level (dB(μ V)/m) = 20 log Emission level (μ V/m)
- (2) The smaller limit shall apply at the cross point between two frequency bands.
- (3) Distance refers to the distance in meters between the measuring instrument, antenna and the closed point of any part of the device or system.



4.4.EUT Configuration on Test

The EN 55032 regulations test method must be used to find the maximum emission during radiated emission test.

The configuration of EUT is the same as used in conducted emission test. Please refer to Section 2.2.

4.5.Operating Condition of EUT

Same as conducted emission test, which is listed in Section 2.2 except the test set up replaced as Section 4.1.

4.6.Test Procedure

The EUT and its simulators are placed on a turned table that is 0.8 meter above the ground. The turned table can rotate 360 degrees to determine the position of the maximum emission level. The EUT is set 3 meters away from the receiving antenna that is mounted on the antenna tower. The antenna can move up and down between 1 meter and 4 meters to find out the maximum emission level. Broadband antenna (calibrated biconical and log periodical antenna) is used as receiving antenna. Both horizontal and vertical polarization of the antenna is set on test. In order to find the maximum emission levels, the interface cable must be manipulated according to EN 55032 on radiated emission test.

The bandwidth setting on the field strength meter (R&S Test Receiver ESCI) is set at 120KHz below 1GHz, set at 1MHz above 1GHz

The frequency range from 30MHz to 1000MHz is checked.

4.7.Test Result

PASS

Please refer to the following page.



Radiation Emission Test Data

Temperature:	24.5 °C	Relative Humidity:	54%
Pressure:	1009hPa	Phase :	Horizontal
Test Voltage :	AC 230V/50Hz	Test Mode:	On mode

80.0 dBuV/m




No.	Mk.	Freq. MHz	Reading Level dBuV	Correct Factor dB	Measure- ment dBuV/m	Limit dB/m	Over dB	Antenna Height cm	Table Degree degree	Comment
1		38.0783	38.60	-15.40	23.20	40.00	-16.80	QP		
2		80.0806	39.02	-19.60	19.42	40.00	-20.58	QP		
3	*	155.9101	44.95	-19.04	25.91	40.00	-14.09	QP		
4		201.3930	41.29	-16.27	25.02	40.00	-14.98	QP		
5		252.0627	36.18	-15.08	21.10	47.00	-25.90	QP		
6		299.3158	33.97	-13.49	20.48	47.00	-26.52	QP		



Radiation Emission Test Data


Temperature:	24.5 °C	Relative Humidity:	54%
Pressure:	1009hPa	Phase :	Vertical
Test Voltage :	AC 230V/50Hz	Test Mode:	On mode



No.	Mk.	Freq. MHz	Reading Level dBuV	Correct Factor dB	Measure- ment dBuV/m	Limit dB/m	Over dB	Antenna Height cm	Table Degree degree	Comment
1	*	42.3022	52.52	-14.41	38.11	40.00	-1.89	QP		
2		78.9652	41.95	-19.41	22.54	40.00	-17.46	QP		
3		135.5062	44.61	-19.28	25.33	40.00	-14.67	QP		
4		199.9856	34.64	-16.28	18.36	40.00	-21.64	QP		
5		248.5518	30.37	-15.16	15.21	47.00	-31.79	QP		
6		311.0867	27.12	-13.54	13.58	47.00	-33.42	QP		

5. HARMONIC CURRENT EMISSION TEST

5.1. Block Diagram of Test Setup



5.2. Test Standard

EN 61000-3-2:2014

5.3. Operating Condition of EUT

- 5.3.1 Setup the EUT as shown in Section 5.1.
- 5.3.2 Turn on the power of all equipments.
- 5.3.3 Let the EUT work in test mode and test it.

5.4. Test Procedure

The power cord of the EUT is connected to the output of the test system. Turn on the power of the EUT and use the test system to test the harmonic current level.

5.5. Test Results

PASS

There is no need for Harmonic current test to be performed on this product (rated power is less than 75 W) in accordance with EN 61000-3-2.

For further details, please refer to Clause 7 of EN 61000-3-2 which states:

“For the following categories of equipment, limits are not specified in this standard:

- equipment with a rated power of 75 W or less, other than lighting equipment.”



6. VOLTAGE FLUCTUATIONS & FLICKER TEST

6.1. Block Diagram of Test Setup

Same as Section 6.1..

6.2. Test Standard

EN 61000-3-3:2013

6.3. Operating Condition of EUT

Same as Section 5.3.. The power cord of the EUT is connected to the output of the test system. Turn on the power of the EUT and use the test system to test the harmonic current level.

Flicker Test Limit

Test items	Limits
Pst	1.0
dc	3.3%
dmax	4.0%
dt	Not exceed 3.3% for 500ms

6.4. Test Procedure

The power cord of the EUT is connected to the output of the test system. Turn on the power of the EUT and use the test system to test the harmonic current level.

6.5. Test Results

PASS

Please refer to the following page.




Flicker Test Data			
Temperature:	24.5 °C	Relative Humidity:	54%
Pressure:	1009hPa		
Test Voltage :	AC230V/50Hz	Test Mode:	ON

Voltage Fluctuation	Limit	Value
Relative Voltage Change Characteristic Tmax (dc>3%)	500 ms	0 ms
Maximum Relative Voltage Change dmax	4%	0.00
	6%	/
	7%	/
Relative Steady-state Voltage Change dc	3.3%	0.00

Flicker	Limit	Value
Short-term Flicker Indicator Pst	1.0	0.064
Long-term Flicker Indicator Plt	0.65	/

7. ELECTROSTATIC DISCHARGE IMMUNITY TEST

7.1. Block Diagram of Test Setup



7.2. Test Standard

EN 55035:2017, EN 61000-4-2:2009

Severity Level: 3 / Air Discharge: $\pm 8\text{KV}$

Level: 2 / Contact Discharge: $\pm 4\text{KV}$

7.3. Severity Levels and Performance Criterion

7.3.1 Severity level

Level	Test Voltage Contact Discharge (KV)	Test Voltage Air Discharge (KV)
1.	± 2	± 2
2.	± 4	± 4
3.	± 6	± 8
4.	± 8	± 15
X	Special	Special



7.3.2 Performance criterion : B

- A. The apparatus shall continue to operate as intended during and after the test. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended.
- B. The apparatus shall continue to operate as intended after the test. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended. The performance level may be replaced by a permissible loss of performance. During the test, degradation of performance is however allowed.
- C. Temporary loss of function is allowed, provided the function is self-recoverable or can be restored by the operation of the controls.

7.4.EUT Configuration

The following equipments are installed on Electrostatic Discharge Immunity test to meet EN 55035:2017, EN 61000-4-2:2009, requirement and operating in a manner which tends to maximize its emission characteristics in a normal application. The configuration of EUT is the same as used in conducted emission test.

Please refer to Section 2.4.

7.5.Operating Condition of EUT

Same as conducted emission measurement, which is listed in Section 3.5 except the test setup replaced by Section 7.1.2.

7.6.Test Procedure

7.6.1 Air Discharge:

This test is done on a non-conductive surface. The round discharge tip of the discharge electrode shall be approached as fast as possible to touch the EUT. After each discharge, the discharge electrode shall be removed from the EUT. The generator is then re-triggered for a new single discharge and repeated 10 times for each pre-selected test point. This procedure shall be repeated until all the air discharge completed.

7.6.2 Contact Discharge:

All the procedure shall be same as Section 7.6.1. Except that the tip of the discharge electrode shall touch the EUT before the discharge switch is operated.



7.6.3 Indirect discharge for horizontal coupling plane

At least 10 single discharges (in the most sensitive polarity) shall be applied at the front edge of each HCP opposite the center point of each unit (if applicable) of the EUT and 0.1m from the front of the EUT. The long axis of the discharge electrode shall be in the plane of the HCP and perpendicular to its front edge during the discharge.

7.6.4 Indirect discharge for vertical coupling plane

At least 10 single discharges (in the most sensitive polarity) shall be applied to the center of one vertical edge of the coupling plane. The coupling plane, of dimensions 0.5m X 0.5m, is placed parallel to, and positioned at a distance of 0.1m from the EUT. Discharges shall be applied to the coupling plane, with this plane in sufficient different positions that the four faces of the EUT are complete illuminated.

7.7. Test Results


PASS

Please refer to the following page.

ESD Test Data				
Temperature:	24.5℃	Humidity:	53%	
Power Supply :	AC230V/50Hz	Test Mode:	On	
Air Discharge: ± 8KV				
Contact Discharge: ± 4KV				
# For each point positive 25 times and negative 25 times discharge				
Test Points	Air Discharge	Contact Discharge	Performance Criterion	Result
Enclosure	N/A	±2,4 KV	B	PASS
Slit	±2,4,8KV	N/A	B	PASS
Metal Part	N/A	±2,4 KV	B	PASS
VCP	N/A	±2,4 KV	B	PASS
HCP	N/A	±2,4 KV	B	PASS
Note: N/A				

8. RF FIELD STRENGTH SUSCEPTIBILITY TEST

8.1. Block Diagram of Test Setup



8.2. Test Standard

EN 55035:2017, EN 61000-4-3: 2006+A1:2008+A2:2010
Severity Level 2, 3V / m



8.3. Severity Levels and Performance Criterion

8.3.1. Severity level

Level	Field Strength V/m
1.	1
2.	3
3.	10
X.	Special

8.3.2. Performance criterion: A

- A、 The apparatus shall continue to operate as intended during and after the test. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended.
- B、 The apparatus shall continue to operate as intended after the test. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended. The performance level may be replaced by a permissible loss of performance. During the test, degradation of performance is however allowed.
- C、 Temporary loss of function is allowed, provided the function is self-recoverable or can be restored by the operation of the controls.

8.4. EUT Configuration on Test

The following equipments are installed on Electrical Fast Transient/Burst Immunity test to meet EN 55035:2017, EN 61000-4-4:2012, requirement and operating in a manner which tends to maximize its emission characteristics in a normal application. The configuration of EUT is the same as used in conducted emission test.
Please refer to Section 3.4.

8.5. Operating Condition of EUT

Same as conducted emission measurement, which is listed in Section 2.5 except the test setup replaced by Section 8.1.



8.6. Test Procedure

The EUT and its simulators are placed on a turn table which is 0.8 meter above ground. EUT is set 3 meter away from the transmitting antenna which is mounted on an antenna tower. Both horizontal and vertical polarization of the antenna are set on test. Each of the four sides of EUT must be faced this transmitting antenna and measured individually.

All the scanning conditions are as follows :

Condition of Test		Remarks
1.	Fielded Strength	3 V/m (Severity Level 2)
2.	Radiated Signal	Modulated
3.	Scanning Frequency	80 - 1000MHz, 1800MHz, 2600MHz, 3500MHz, 5000MHz
4.	Dwell time of radiated	0.0015 decade/s
5.	Waiting Time	1 Sec.

8.7. Test Results

PASS


Please refer to the following page.

R/S Test Data			
Temperature : 25℃		Humidity : 53%	
Field Strength: 3 V/m		Criterion: A	
Power Supply: AC230V/50Hz		Frequency Range: 80 - 1000MHz, 1800MHz,2600MHz, 3500MHz,5000MHz	
Modulation:		<input checked="" type="checkbox"/> AM	<input type="checkbox"/> Pulse
		<input type="checkbox"/> none	1 KHz 80%
Test Mode : On			
	Frequency Range : 80 - 1000MHz,1800MHz,2600MHz, 3500MHz,5000MHz		
Steps	1 %		
	Horizontal	Vertical	Result
Front	A	A	Pass
Right	A	A	Pass
Rear	A	A	Pass
Left	A	A	Pass
Note: N/A			



9. ELECTRICAL FAST TRANSIENT/BURST IMMUNITY TEST

9.1. Block Diagram of EUT Test Setup



9.2. Test Standard

EN 55035:2017, EN 61000-4-4:2012

9.3. Severity Levels and Performance Criterion

Severity Level 2 at 1KV, Pulse Rise time & Duration: 5 nS / 50 nS

Severity Level:

Open Circuit Output Test Voltage $\pm 10\%$		
Level	On power ports	On I/O(Input/Output) Signal data and control ports
1.	0.5KV	0.25KV
2.	1KV	0.5KV
3.	2KV	1KV
4.	4KV	2KV
X.	Special	Special

Performance criterion: B

- A. The apparatus shall continue to operate as intended during and after the test. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended.
- B. The apparatus shall continue to operate as intended after the test. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended. The performance level may be replaced by a permissible loss of performance. During the test, degradation of performance is however allowed.
- C. Temporary loss of function is allowed, provided the function is self-recoverable or can be restored by the operation of the controls.



9.4.EUT Configuration on Test

The following equipments are installed on Electrical Fast Transient/Burst Immunity test to meet EN 55035:2017, EN 61000-4-4:2012, requirement and operating in a manner which tends to maximize its emission characteristics in a normal application. The configuration of EUT is the same as used in conducted emission test.

Please refer to Section 3.4.

9.5.Operating Condition of EUT

Same as conducted emission measurement, which is listed in Section 2.6 except the test setup replaced by Section 9.1.

9.6.Test Procedure

EUT shall be placed 0.8m high above the ground reference plane which is a min.1m*1m metallic sheet with 0.65mm minimum thickness. This reference ground plane shall project beyond the EUT by at least 0.1m on all sides and the minimum distance between EUT and all other conductive structure, except the ground plane beneath the EUT, shall be more than 0.5m

9.6.1. For input and output AC power ports:

The EUT is connected to the power mains by using a coupling device which couples the EFT interference signal to AC power lines. Both polarities of the test voltage should be applied during compliance test and the duration of the test is 2 minutes.



9.7. Test Results

PASS

Please refer to the following page.

EFT Test Data				
Temperature:	24.5℃		Humidity:	53%
Power Supply :	AC230V/50Hz		Test Mode:	On
Coupling Line	Test Voltage		Performance Criterion	Result
	±0.5kV	±1kV		
L	±0.5kV	±1kV	B	PASS
N	±0.5kV	±1kV	B	PASS
L-N	±0.5kV	±1kV	B	PASS
PE	±0.5kV	±1kV	B	N/A
L-PE	±0.5kV	±1kV	B	N/A
N-PE	±0.5kV	±1kV	B	N/A
L-N-PE	±0.5kV	±1kV	B	N/A
DC Line	/	/		/
Note: N/A				



10. SURGE TEST

10.1. Block Diagram of EUT Test Setup



10.2. Test Standard

EN 55035:2017, EN61000-4-5:2014

10.3. Severity Levels and Performance Criterion

Severity Level: Line to Line, Level 2 at 1KV;

Severity Level: Line to Earth, Level 3 at 2KV.

Severity Level	Open-Circuit Test Voltage (KV)
1.	0.5
2.	1.0
3.	2.0
4.	4.0
X.	Special

Performance criterion: B

- The apparatus shall continue to operate as intended during and after the test. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended.
- The apparatus shall continue to operate as intended after the test. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended. The performance level may be replaced by a permissible loss of performance. During the test, degradation of performance is however allowed.
- Temporary loss of function is allowed, provided the function is self-recoverable or can be restored by the operation of the controls.



10.4. EUT Configuration on Test

The following equipments are installed on Electrical Fast Transient/Burst Immunity test to meet EN 55035:2017, EN61000-4-5:2014, requirement and operating in a manner which tends to maximize its emission characteristics in a normal application

The configuration of EUT is the same as used in conducted emission test. Please refer to Section 3.4.

10.5. Operating Condition of EUT

Same as conducted emission measurement, which is listed in Section 2.7 except the test setup replaced by Section 10.1.

10.6. Test Procedure

- 1) Set up the EUT and test generator as shown on section 10.1
- 2) For line to line coupling mode, provide a 1KV 1.2/50us voltage surge (at open-circuit condition) and 8/20us current surge to EUT selected points.
- 3) At least 5 positive and 5 negative (polarity) tests with a maximum 1/min repetition rate are conducted during test.
- 4) Different phase angles are done individually.
- 5) Repeat procedure 2) to 4) except the open-circuit test voltage change from 1KV to 2KV for line to earth coupling mode test.
- 6) Record the EUT operating situation during compliance test and decide the EUT immunity criterion for above each test.



10.7. Test Result

PASS

Please refer to the following page.

Surge Test Data						
Temperature:	24.5℃		Humidity:	53%		
Power Supply :	AC230V/50Hz		Test Mode:	On		
Location	Polarity	Phase Angle	No of Pulse	Pulse Voltage (KV)	Performance Criterion	Result
L-N	+	90	5	1	B	Pass
	-	270	5	1		Pass
L-PE	+	90	5	2		N/A
	-	270	5	2		N/A
N-PE	+	90	5	2		N/A
	-	270	5	2		N/A
Note: N/A						


11. INJECTED CURRENTS SUSCEPTIBILITY TEST

11.1. Block Diagram of EUT Test Setup

11.1.1. Block Diagram of EUT Test Setup



11.1.2. Block Diagram of Test Setup



11.2. Test Standard

EN 55035:2017, EN61000-4-6:2014

11.3. Severity Levels and Performance Criterion

Severity Level 2: 3V(rms), 150KHz ~ 80MHz

Severity Level:

Level	Field Strength V
1.	1
2.	3
3.	10
X.	Special



Performance criterion: A

- A. The apparatus shall continue to operate as intended during and after the test. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended.
- B. The apparatus shall continue to operate as intended after the test. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended. The performance level may be replaced by a permissible loss of performance. During the test, degradation of performance is however allowed.
- C. Temporary loss of function is allowed, provided the function is self-recoverable or can be restored by the operation of the controls.

11.4. EUT Configuration on Test

The configuration of EUT is the same as used in conducted emission test. Please refer to Section 2.8.

11.5. Operating Condition of EUT

Same as conducted emission test, which is listed in Section 2.8 except the test set up replaced as Section 11.1.

11.6. Test Procedure

- 1) Set up the EUT, CDN and test generator as shown on section 11.1
- 2) Let EUT work in test mode and measure.
- 3) The EUT and supporting equipments are placed on an insulating support 0.1m high above a ground reference plane. CDN (coupling and decoupling device) is placed on the ground plane at above 0.1-0.3m from EUT. Cables between CDN and EUT are as short as possible, and their height above the ground reference plane shall be between 30 and 50 mm (where possible).
- 4) The disturbance signal described below is injected to EUT through CDN.
- 5) The EUT operates within its operational mode(s) under intended climatic conditions after power on.
- 6) The frequency range is swept from 150KHz to 80MHz using 3V signal level, and with the disturbance signal 80% amplitude modulated with a 1KHz sine wave
- 7) The rate of sweep shall not exceed 1.5×10^{-3} decades/s. Where the frequency is swept incrementally, the step size shall not exceed 1% of the start and thereafter 1% of the preceding frequency value.



- 8) Recording the EUT operating situation during compliance test and decide the EUT immunity criterion for above each test.

11.7. Test Result


PASS

Please refer to the following page.

Inject Line	Frequency (MHz)	Voltage Level (V r.m.s.)	Required Level	Performance Criterion
a.c. port	0.15 - 10	3	A	A
	10 to 30	3 to 1	A	A
	30 to 80	1	A	A
Note: N/A				

12. MAGNETIC FIELD IMMUNITY TEST

12.1. Block Diagram of Test Setup



12.2. Test Standard

EN 55035:2017, EN61000-4-8:2010
Severity Level 1 at 1A/m

12.3. Severity Levels and Performance Criterion

12.3.1 Severity level

Level	Magnetic Field Strength A/m
1.	1
2.	3
3.	10
4.	30
5.	100
X.	Special

12.3.2 Performance criterion: B

- A. The apparatus shall continue to operate as intended during and after the test. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended.
- B. The apparatus shall continue to operate as intended after the test. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended. The performance level may be replaced by a permissible loss of performance. During the test, degradation of performance is however allowed.
- C. Temporary loss of function is allowed, provided the function is



self-recoverable or can be restored by the operation of the controls.

12.4. EUT Configuration on Test

The configuration of EUT is listed in Section 2.9.

12.5. Operating Condition of EUT

Same as conducted emission test, which is listed in Section 2.9 except the test set up replaced as Section 12.1.

12.6. Test Procedure

The EUT shall be subjected to the test magnetic field by using the induction coil of standard dimensions (1m*1m) and shown in Section 10.1. The induction coil shall then be rotated by 90° in order to expose the EUT to the test field with different orientations.

12.7. Test Results

PASS


Please refer to the following page.

MS Test Data					
Temperature:	24.5℃		Humidity:	53%	
Power Supply :	AC230V/50Hz		Test Mode:	On	
Environmental Phenomena	Test specification	Units	Coil Orientation	Performance Criterion	Result
Magnetic Field	1	A/m	X	A	PASS
			Y	A	PASS
			Z	A	PASS
Note: N/A					



13. VOLTAGE DIPS AND INTERRUPTIONS TEST

13.1. Block Diagram of EUT Test Setup



13.2. Test Standard

EN 55035:2017, EN61000-4-11:2004

13.3. Severity Levels and Performance Criterion

Severity Level:

Input and Output AC Power Ports.

- ☒ Voltage Dips.
- ☒ Voltage Interruptions.

Environmental Phenomena	Test Specification	Units	Performance Criterion
Voltage Dips	>95 0.5	% Reduction period	B
	30 25	% Reduction period	C
Voltage Interruptions	>95 250	% Reduction period	C

Performance criterion: B, C, C

- A. The apparatus shall continue to operate as intended during and after the test. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended.
- B. The apparatus shall continue to operate as intended after the test. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended. The performance level may be replaced by a permissible loss of performance. During the test, degradation of performance is however allowed.
- C. Temporary loss of function is allowed, provided the function is self-recoverable or can be restored by the operation of the controls.



13.4. EUT Configuration on Test

The configuration of EUT is the same as used in conducted emission test. Please refer to Section 2.10.

13.5. Operating Condition of EUT

Same as conducted emission test, which is listed in Section 2.10 except the test set up replaced as Section 13.1.

13.6. Test Procedure

- 1) Set up the EUT and test generator as shown on section 13.1
- 2) The interruption is introduced at selected phase angles with specified duration. There is a 3mins minimum interval between each test event.
- 3) After each test a full functional check is performed before the next test.
- 4) Repeat procedures 2 & 3 for voltage dips, only the level and duration is changed.
- 5) Record any degradation of performance.

13.7. Test Result

PASS

Please refer to the following page.

DIPS Test Data			
Temperature:	24.5°C	Humidity:	53%
Power Supply :	AC230V/50Hz	Test Mode:	On
Environmental Phenomena	Test Specification	Units	Performance Criterion
Voltage Dips	>95	% Reduction period	B
	0.5		
	30 25	% Reduction period	C
Voltage Interruptions	>95 250	% Reduction period	C

14. EUT PHOTOGRAPHS

EUT Photo 1



EUT Photo 2







EUT Photo 3




EUT Photo 4



EUT Photo 5



EUT Photo 6




15. EUT TEST PHOTOGRAPHS

CE




RE







ESD




RS



CS



Surge&EFT&Dips



***** END OF REPORT *****